

Date	Res. Chlorine	BACTERIAL RESULTS																REMARKS				
		BACTERIA PER C.C.								B. COLI												
		Gel. 20° 48 hrs.				Agar 37° 24 hrs.				Raw				Filtered					Disinf.			
		Raw	Settled	Filt.	Disinf.	Raw	Settled	Filt.	Disinf.	.01	.1	1	10	.1	1	10	1		10			
1	.3																	"B" Seam				
2	.3							2	1	1	1	(Local Test)						" "				
3	.3							1	1	1	1	(Pub. Service Lab. Test)						" "				
4	.3																	" "				
5	.3																	" "				
6	.3																	" " & Branches				
7	.3																	" "				
8	.3																	" "				
9	.4							2	1	1	1	(Local Test)						" "				
10	.4																	" "				
11	.4																	" "				
12	.4																	" "				
13	.4																	"B" Seam & "				
14	.3																	" " " "				
15	.3																	" " " "				
16	.4							2	1	1	1	(Local Test)						" " " "				
17	.4																	" " " "				
18	.4																	" " " "				
19	.3																	" " " "				
20	.4																	" " " "				
21	.4																	" " " "				
22	.3																	" " " "				
23	.4							2	1	1	1	(Local Test)						" " " "				
24	.4																	" " " "				
25	.4																	" " " "				
26	.4																	" " " "				
27	.4																	" " " "				
28	.3																	" " " "				
29	.3																	" " " "				
30	.3							2	1	1	1	(Local Test)						" " " "				
																		Note:-Activated-Carbon				
	3.5																	used. Alum-carbon Ratio				
	.4																	20 : 3/4				
	.3																					

COMMONWEALTH OF KENTUCKY
DEPARTMENT OF HEALTH
BUREAU OF SANITARY ENGINEERING

Report of Operation for Water Purification Plant
at Benham, Harlan County, Kentucky
for the month of November, 1936

Note: The following blanks are not to be filled out by sender.

Received
Acknowledged
Abstract By.....
Filed

Reports are to be sent in Monthly.

SIGNED W. H. Boatright MONTH November
Chief Engineer Title. YEAR 1936

W. H. Boatright
12/11/36