

Date (A.7.3+4) Time Reported - Report + Repair
1/13/72 10:00 a.m. Mrs. Turner reported gas
leak in water & thought pressure
was too variable
✓ 10:15 a.m. - Willie Bryant found that
the water heater had gone
out without any apparent reason.

1/19/72 (394) 10:30 a.m. gas leak reported by Mrs.
Mullins

✓ 10:45 a.m. - Willie Bryant
repaired gas leak in line
12:45 leading to heater. (Tightened
fitting, leak was not
in our line but in customer's
heater.)

1/22/72 (A.12-1) 9:00 - gas leak report by Vern
Bailey

✓ 9:20. Call was answered & repaired
by 10:40 (new packing
around index)

1/25/72 Fountain 9:15 gas leak reported by Mrs.
Hall

✓ 9:20 call was taken by Lou
Halbrook who found a
hole in cooling system ^{the}
an old cooler, he drained
this cooler for safety. Complete
job at 10:20.