(INDIVIDUAL)

FIRE HYDRANT RECORD

Hydrant No. 1

Location Upper Atlas

Date Installed 1947 Manufacturer's Name Mueller

Size of Valve Opening 4" No. of Outlets: 2½" 1, 4½"

Size of Branch Line 4" Auxiliary Gate Valve yes Size of Street Main 6"

Size and Type of Operating Nut 1¼" square type

Remarks:

Date Inspected	Static Pressure	Flow	Remarks: As to Condition and Repair	Name
8-20-73	80 lb		Good grease + new gasket	
			Check By	
			Claud Cook	
			and	
			[illegible]	
			[illegible]	

NOTE 1 INSPECT EACH HYDRANT THREE TIMES ANNUALLY INCLUDING TEST OF HYDRANT VALVE

2. OBSERVE FLOW EACH INSPECTION DURING INSPECTION TEST

3. INDICATE FLOW VOLUME IN WHICH EVENT GIVEN